

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PRIVATE SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Unsatisfactory**

Permit Number: 53-51-02123  
Name of Facility: McKeel Academy  
Address: 411 N Florida Avenue  
City, Zip: Lakeland 33801

**Correct By: by 8:00 AM**  
**Re-Inspection Date: 1/5/2021**

Type: Private Charter School  
Owner: McKeel Elementary Academy Inc  
Person In Charge: Backes, Dan Phone: (863) 499-1287  
PIC Email: danbackes@mckeelschools.com

**Inspection Information**

Purpose: Routine  
Inspection Date: 12/8/2020

Begin Time: 02:30 PM  
End Time: 03:15 PM

**Additional Information**

FEMALES ..... 318  
MALES ..... 296

CENSUS ..... 614

*As per section 120.695, Florida Statutes (FS) this form will serve as a "Notice of Non-Compliance" for any violation noted. Items marked below violate one or more of the requirements of Chapter 6A-2.0040 Florida Administrative Code (FAC). Sanitation Standards in K-12 Private Schools and section 468. Florida Building Code (FBC), Schools, Colleges, and Universities. Violations must be corrected within the time period indicated in the results section above. Continued operation of this facility without making these corrections is a violation of section 6A-2.0040, FAC, and section 468 FBC. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION	<b>IN</b> 13. Disinfectants	SAFETY
<b>IN</b> 1. School Site	<b>IN</b> 14. Handwash Facilities	<b>IN</b> 25. First Aid Kit
<b>IN</b> 2. Playground	<b>IN</b> 15. Soap Dispensers	DIAPER CHANGING STATION
<b>IN</b> 3. Athletic Equipment	<b>NA</b> 16. Showers	<b>NA</b> 26. Location/Sanitizers
BUILDING	<b>NA</b> 17. Shower Water Temperature	<b>NA</b> 27. Changing Station & Mats
<b>IN</b> 4. Construction	WATER SUPPLY	<b>NA</b> 28. Handsink
<b>IN</b> 5. Maintenance & Repair	<b>IN</b> 18. Approved Source	<b>NA</b> 29. Garbage Can
<b>IN</b> 6. Lighting Standards	<b>IN</b> 19. Drinking Fountains	ANIMAL HEALTH AND SAFETY
<b>IN</b> 7. Heating, Ventilation, A/C	LIQUID WASTE	<b>NA</b> 30. Vaccination
<b>IN</b> 8. Natural Ventilation	<b>IN</b> 20. Sewage Disposal	<b>NA</b> 31. Animal Maintenance/Aggressive Animals
<b>IN</b> 9. Mechanical Ventilation	<b>IN</b> 21. Solid Waste	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	PEST CONTROL	<b>NA</b> 32. Maintenance/Complaint
<b>IN</b> 10. Provided/Accessible	<b>IN</b> 22. Pest Control	<b>NA</b> 33. Other
<b>OUT</b> 11. Toilet Floor Drains	<b>IN</b> 23. Brush /Trash	
<b>IN</b> 12. Toilet Facilities	<b>IN</b> 24. Water Collection/Drainage	

*IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

**General Comments**

No hose bibs were installed since previous inspection. Inspection will be classified as Unsatisfactory until the required items are installed. A period of 30 days will be given for installation (or contact for an extension if needed).

Email Address(es): danbackes@mckeelschools.com

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PRIVATE SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #11. Toilet Floor Drains  
Male and female group restrooms in Building "A" and the second floor of Building B do not have hose bibs present.  
CODE REFERENCE: Toilet Floor Drains. 6A-2.0040(6)(a)1 and FBC 468.3.5.6. All group toilet rooms shall be provided with at least one (1) floor drain & (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Jared Williams (35264)  
Inspector Contact Number: Work: (863) 519-8330 ex.  
Print Client Name: Dan Backes  
Date: 12/8/2020

Inspector Signature:

Handwritten signature of Jared Williams.

Client Signature:

Handwritten signature of Dan Backes.